

Indoor Distribution Test Report

Spectrum Lighting Inc.

994 Jefferson Street
Fall River, MA 02721
+1.508.678.2303

Spectrum Lighting Photometric Lab

Luminaire

IF03SSx IC 835 010 N11 DLNFGN MW
Nom 3" Square Infinium recessed downlight

Test Number

SP-00779_1_M-010L

Test Date

The results contained in this report pertain only to this IES file.

Summary of Results

Power

Input Watts	7.3 W
-------------	-------

Lumen Output

Output Lumens	519
Efficacy	71.04 lm/W

Luminous Dimensions

0° - 180° Size	0.16
90° - 270° Size	0.16
Height	0

Spacing Criterion

Two luminaires, plane 0°	0.51
Two luminaires, plane 90°	0.51
Four luminaires	0.56


Full Beam Angle

0° - 180°	31°
90° - 270°	31°

IES File Header Contents

Keyword	Value
TEST	SP-00779_1_M-010L
TESTLAB	Spectrum Lighting Photometric Lab, VLS-245-981
MANUFAC	Spectrum Lighting
ISSUEDATE	2/11/2019
UPDATE	3/11/2019
LUMCAT	IF03SSx IC 835 010 N11 DLNFGN MW
LUMINAIRE	Nom 3" Square Infinium recessed downlight
OTHER	Beam Angle: 31 degrees
OTHER	Narrow Flood optic, Open aperture / no lens
OTHER	Aluminum bezel
LAMPCAT	N/A
LAMP	N/A, CRI: 80, Philips
OTHER	CCT Multiplier: 40K x 1.03
OTHER	Total luminaire wattage is approximate
OTHER	This report prepared by Spectrum Lighting, scaled from 20L

Candela Polar Plot



Zonal Lumen Summary

Zone	Lumens	% Fixture	Zone	Lumens	% Fixture
0.00° - 10.00°	116.64	22.49%	90.00° - 100.00°	0.04	0.01%
10.00° - 20.00°	198.47	38.27%	100.00° - 110.00°	0.00	0.00%
20.00° - 30.00°	132.06	25.46%	100.00° - 120.00°	0.00	0.00%
30.00° - 40.00°	37.16	7.17%	120.00° - 130.00°	0.00	0.00%
40.00° - 50.00°	10.09	1.95%	130.00° - 140.00°	0.00	0.00%
50.00° - 60.00°	7.92	1.53%	140.00° - 150.00°	0.00	0.00%
60.00° - 70.00°	11.15	2.15%	150.00° - 160.00°	0.00	0.00%
70.00° - 80.00°	4.07	0.78%	160.00° - 170.00°	0.00	0.00%
80.00° - 90.00°	1.02	0.20%	170.00° - 180.00°	0.00	0.00%
0.00° - 90.00°	518.58	99.99%	0.00° - 180.00°	518.62	100.00%

Candela Distribution

	0.00°	22.50°	45.00°	67.50°	90.00°	112.50°	135.00°	157.50°	180.00°	202.50°	225.00°	247.50°	270.00°	292.50°	315.00°	337.50°	360.00°
0.00°	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99	1,412.99
2.50°	1,372.47	1,389.72	1,376.68	1,380.75	1,370.99	1,382.43	1,373.73	1,383.95	1,379.39	1,396.10	1,383.72	1,385.10	1,376.75	1,384.29	1,374.73	1,381.44	1,372.47
5.00°	1,311.47	1,289.76	1,293.40	1,292.55	1,305.52	1,302.79	1,310.64	1,304.34	1,324.42	1,304.93	1,302.68	1,302.19	1,316.98	1,308.18	1,315.99	1,297.55	1,311.47
7.50°	1,178.20	1,176.37	1,165.08	1,175.17	1,180.55	1,179.48	1,167.29	1,184.63	1,197.91	1,198.93	1,169.75	1,184.62	1,193.15	1,190.33	1,168.54	1,178.50	1,178.20
10.00°	1,043.27	1,023.29	1,004.49	1,022.52	1,046.18	1,032.56	1,020.20	1,035.91	1,066.93	1,039.26	1,018.29	1,033.75	1,058.81	1,038.86	1,015.81	1,027.75	1,043.27
12.50°	890.14	871.29	853.96	869.77	893.60	869.71	858.83	869.80	903.24	873.52	852.76	868.49	898.42	882.68	861.16	874.61	890.14
15.00°	739.38	721.82	709.21	716.92	739.35	721.90	708.11	719.00	741.91	721.97	709.37	716.60	742.16	723.39	708.46	719.68	739.38
17.50°	604.06	586.62	595.86	592.06	608.40	582.19	588.31	575.50	592.50	571.21	579.89	569.33	594.04	589.29	596.57	591.91	604.06
20.00°	473.57	477.37	496.75	489.36	478.59	474.75	485.04	460.97	450.77	458.51	486.53	454.26	456.88	468.60	489.04	480.51	473.57
22.50°	364.77	378.88	426.15	398.60	369.42	381.21	419.36	357.13	336.46	347.30	411.21	347.42	337.21	366.65	423.13	385.77	364.77
25.00°	262.23	296.28	365.91	315.67	261.82	294.07	350.76	273.11	231.95	264.88	332.92	258.17	231.00	272.55	355.20	298.97	262.23
27.50°	180.16	219.76	296.15	234.15	175.86	209.08	276.92	194.82	153.80	184.48	253.45	172.05	142.01	189.72	275.59	221.78	180.16
30.00°	108.55	150.60	223.81	153.36	95.62	139.63	206.74	132.12	89.07	122.58	184.64	110.49	79.39	110.56	199.27	148.29	108.55
32.50°	63.39	94.39	161.34	95.19	58.81	74.03	141.90	72.64	53.27	66.52	119.11	51.81	44.45	66.84	136.42	93.87	63.39
35.00°	30.41	50.87	100.76	46.30	27.11	46.02	89.54	46.30	28.56	43.27	75.68	35.31	25.45	31.80	80.81	44.99	30.41
37.50°	21.83	26.71	62.56	27.25	21.17	24.83	52.05	24.40	22.76	23.71	37.17	21.16	20.18	22.30	47.36	27.85	21.83
40.00°	15.73	18.10	27.28	17.90	16.15	18.62	28.87	19.55	18.32	18.87	24.51	17.84	16.74	17.09	22.04	17.48	15.73
42.50°	13.55	13.09	18.16	14.19	14.49	14.10	19.48	16.03	15.72	14.83	15.81	14.59	14.57	14.37	15.85	13.94	13.55
45.00°	11.71	10.45	10.80	11.83	12.76	12.92	14.12	13.45	13.81	13.18	13.07	12.48	12.59	11.91	11.28	11.38	11.71
47.50°	10.31	8.94	9.71	10.59	10.83	11.92	11.94	10.94	12.66	11.55	10.87	10.45	10.71	10.20	9.84	9.66	10.31
50.00°	8.69	8.02	8.69	9.54	9.14	10.07	10.75	10.09	11.26	9.99	10.56	9.20	9.27	8.55	8.72	8.02	8.69
52.50°	6.84	7.44	7.97	8.87	7.96	8.31	10.19	9.30	9.63	8.95	10.31	8.17	8.02	8.23	8.10	7.77	6.84
55.00°	6.03	6.99	7.48	8.22	7.42	8.35	10.46	9.23	8.58	8.89	10.34	8.36	7.64	7.97	8.36	7.56	6.03
57.50°	6.11	7.79	9.47	9.11	7.96	8.62	11.16	9.43	7.98	9.57	10.48	8.87	7.55	8.64	9.71	7.62	6.11
60.00°	7.36	9.00	11.19	10.08	9.58	10.94	12.55	11.54	9.34	11.36	12.15	10.69	8.90	9.45	10.99	7.84	7.36
62.50°	9.44	10.30	11.32	11.63	12.69	13.01	14.22	13.35	11.89	12.56	13.54	12.06	10.64	11.39	12.19	9.96	9.44
65.00°	10.57	11.62	11.13	12.97	13.65	13.73	13.14	13.85	12.79	13.06	13.02	12.12	11.69	12.70	11.67	11.62	10.57
67.50°	11.15	10.51	9.54	10.94	12.16	13.20	11.21	12.93	12.93	11.24	11.38	10.87	12.56	10.87	9.73	10.34	11.15
70.00°	9.29	8.99	7.72	8.68	9.47	9.07	8.18	8.66	9.14	7.61	6.68	7.45	8.50	8.66	7.34	8.58	9.29
72.50°	6.55	6.40	5.40	5.43	5.90	5.80	5.26	5.16	5.03	4.29	3.85	4.65	4.92	5.69	4.71	5.56	6.55
75.00°	4.09	4.18	3.78	3.28	3.71	3.34	3.04	2.32	2.42	1.78	2.42	2.39	2.28	3.41	3.52	3.61	4.09
77.50°	2.73	2.63	2.69	2.22	2.22	2.15	1.94	1.71	1.71	1.20	1.71	1.43	1.60	1.79	2.66	2.47	2.73
80.00°	2.81	2.55	2.45	1.97	1.84	1.52	1.36	1.50	1.40	1.49	1.34	1.02	1.18	1.65	2.13	2.10	2.81
82.50°	1.85	2.02	1.98	1.68	1.38	1.13	0.98	1.15	0.85	0.94	1.08	0.85	0.81	1.27	1.47	1.82	1.85
85.00°	0.77	1.00	1.10	1.12	0.74	0.63	0.80	0.58	0.71	0.56	0.57	0.64	0.51	0.70	0.91	1.11	0.77
87.50°	0.61	0.60	0.61	0.89	0.49	0.60	0.63	0.81	0.57	0.58	0.45	0.61	0.63	0.63	0.59	0.70	0.61
90.00°	0.48	0.44	0.54	0.81	0.53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.55	0.67	0.63	0.48
92.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
95.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
97.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
102.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
105.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
107.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
110.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
112.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Coefficients of Utilization – Zonal Cavity Method

Values are lumens delivered to the workplane.

RCR	pfc	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	0%
	pcc	80%	80%	80%	80%	70%	70%	70%	70%	50%	50%	50%	30%	30%	30%	10%	10%	0%
	pw	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	30%
	0	617	617	617	617	603	603	603	603	576	576	576	552	552	552	529	529	519
	1	591	578	566	555	578	566	556	546	546	537	529	526	520	514	509	504	499
	2	566	543	524	508	554	534	517	502	517	503	491	502	491	481	488	479	471
	3	542	512	489	471	532	505	484	467	492	474	460	480	465	453	468	456	446
	4	520	486	460	441	511	480	457	439	469	449	434	459	442	429	450	436	424
	5	500	462	436	416	492	457	433	415	448	427	411	440	422	407	433	417	404
	6	480	441	414	395	473	437	412	394	430	408	391	423	403	389	416	399	386
	7	463	422	395	376	456	418	393	375	412	390	374	406	387	372	401	383	370
	8	446	404	378	360	440	401	376	359	396	374	358	391	371	356	387	368	355
	9	430	388	362	345	425	386	361	344	381	359	343	377	357	342	373	355	341
	10	416	373	348	331	411	371	347	331	368	345	330	364	344	329	361	342	328

Cone of Light

Mtg Height	Light Level	Beam Diameter
5.5 ft	46.7 fc	3.1 ft
6.5 ft	33.4 fc	3.6 ft
7.5 ft	25.1 fc	4.2 ft
8.0 ft	22.1 fc	4.5 ft
10.0 ft	14.1 fc	5.6 ft
12.0 ft	9.8 fc	6.7 ft
14.0 ft	7.2 fc	7.8 ft
16.0 ft	5.5 fc	8.9 ft
20.0 ft	3.5 fc	11.2 ft
24.0 ft	2.5 fc	13.4 ft
28.0 ft	1.8 fc	15.7 ft

Average Luminaire Luminance [cd/m²]

	0.00°	45.00°	90.00°
0.00°	594,113	594,113	594,113
45.00°	6,966	6,424	7,586
55.00°	4,419	5,485	5,436
65.00°	10,512	11,071	13,581
75.00°	6,648	6,139	6,024
85.00°	3,723	5,293	3,567

UGR CIE 190:2010

Ceiling reflectance		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall reflectance		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Plane reflectance		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
2H	2H	10.7	11.7	11.1	12.0	12.3	11.8	12.8	12.1	13.1	13.4
	3H	15.7	16.6	16.1	16.9	17.3	16.3	17.1	16.7	17.5	17.8
	4H	16.2	17.0	16.6	17.4	17.8	16.5	17.3	16.9	17.7	18.1
	6H	16.5	17.2	16.9	17.6	18.0	16.6	17.3	17.0	17.7	18.1
	8H	16.6	17.3	17.0	17.7	18.1	16.6	17.2	17.0	17.6	18.1
	12H	16.6	17.3	17.1	17.7	18.1	16.5	17.2	17.0	17.6	18.0
4H	2H	13.0	13.8	13.4	14.1	14.5	14.0	14.8	14.4	15.2	15.5
	3H	16.8	17.4	17.2	17.8	18.2	17.3	17.9	17.7	18.3	18.7
	4H	17.3	17.9	17.7	18.3	18.7	17.5	18.1	17.9	18.5	18.9
	6H	17.6	18.1	18.0	18.5	19.0	17.5	18.0	18.0	18.5	19.0
	8H	17.7	18.2	18.2	18.6	19.1	17.5	18.0	18.0	18.5	18.9
	12H	17.8	18.2	18.3	18.7	19.1	17.5	17.9	18.0	18.4	18.9
8H	4H	17.3	17.8	17.8	18.3	18.7	17.5	17.9	17.9	18.4	18.9
	6H	17.8	18.1	18.3	18.6	19.1	17.5	17.9	18.1	18.4	18.9
	8H	18.0	18.3	18.5	18.8	19.3	17.6	17.9	18.1	18.4	18.9
	12H	18.1	18.4	18.6	18.9	19.5	17.6	17.9	18.1	18.4	19.0
12H	4H	17.3	17.7	17.8	18.2	18.7	17.4	17.8	17.9	18.3	18.8
	6H	17.8	18.1	18.3	18.6	19.1	17.5	17.8	18.0	18.3	18.9
	8H	18.0	18.3	18.6	18.8	19.4	17.6	17.8	18.1	18.3	18.9

Corrected UGR values based on total output lumens

SHR = 1.0