

## Indoor Distribution Test Report

# Spectrum Lighting Inc.

994 Jefferson Street  
Fall River, MA 02721  
+1.508.678.2303

## Spectrum Lighting Photometric Lab

### Luminaire

C0614LM 100L 35K ND DX NL CD XX  
Nom 6" diam x 14" H 100L Cylinder for Whole Foods project

### Test Number

SP-01023

### Test Date

1/15/2020

The results contained in this report pertain only to this IES file.

### Summary of Results

#### Power

Input Watts	73.6 W
-------------	--------

#### Lumen Output

Output Lumens	7256
Efficacy	98.59 lm/W

#### Luminous Dimensions

0° - 180° Size	-0.5
90° - 270° Size	-0.5
Height	0

#### Spacing Criterion

Two luminaires, plane 0°	0.42
Two luminaires, plane 90°	0.42
Four luminaires	0.48


#### Full Beam Angle

0° - 180°	25°
90° - 270°	25°

### IES File Header Contents

Keyword	Value
TEST	SP-01023
TESTLAB	Spectrum Lighting Photometric Lab, VLS-245-981
MANUFAC	Spectrum Lighting
TESTDATE	1/15/2020
ISSUEDATE	2/5/2020
LUMCAT	C0614LM 100L 35K ND DX NL CD XX
LUMINAIRE	Nom 6" diam x 14" H 100L Cylinder for Whole Foods project
OTHER	Beam Angle: 25.1 degrees
OTHER	Narrow Optic
LAMPCAT	N/A
LAMP	N/A
OTHER	CCT Output Multipliers: 27K x .934, 30K x .963, 40K x 1.02, 50K x 1.03
OTHER	Total luminaire wattage is approximate
OTHER	This report prepared by Spectrum Lighting

**Candela Polar Plot**



**Zonal Lumen Summary**

Zone	Lumens	% Fixture	Zone	Lumens	% Fixture
0.00° - 10.00°	1,548.84	21.21%	90.00° - 100.00°	0.69	0.01%
10.00° - 20.00°	2,163.65	29.62%	100.00° - 110.00°	0.00	0.00%
20.00° - 30.00°	1,891.14	25.89%	100.00° - 120.00°	0.00	0.00%
30.00° - 40.00°	1,305.72	17.88%	120.00° - 130.00°	0.00	0.00%
40.00° - 50.00°	253.65	3.47%	130.00° - 140.00°	0.00	0.00%
50.00° - 60.00°	89.82	1.23%	140.00° - 150.00°	0.00	0.00%
60.00° - 70.00°	31.38	0.43%	150.00° - 160.00°	0.00	0.00%
70.00° - 80.00°	11.54	0.16%	160.00° - 170.00°	0.00	0.00%
80.00° - 90.00°	7.38	0.10%	170.00° - 180.00°	0.00	0.00%
0.00° - 90.00°	7,303.12	99.99%	0.00° - 180.00°	7,303.81	100.00%

### Candela Distribution

	0.00°	45.00°	90.00°
0.00°	19,216.46	19,216.46	19,216.46
2.50°	19,216.46	19,216.46	19,216.46
5.00°	17,240.68	17,240.68	17,240.68
7.50°	15,017.75	15,017.75	15,017.75
10.00°	12,316.89	12,316.89	12,316.89
12.50°	9,551.18	9,551.18	9,551.18
15.00°	7,770.54	7,770.54	7,770.54
17.50°	6,131.37	6,131.37	6,131.37
20.00°	5,269.43	5,269.43	5,269.43
22.50°	4,525.16	4,525.16	4,525.16
25.00°	4,090.05	4,090.05	4,090.05
27.50°	3,705.17	3,705.17	3,705.17
30.00°	3,305.55	3,305.55	3,305.55
32.50°	2,903.41	2,903.41	2,903.41
35.00°	2,178.20	2,178.20	2,178.20
37.50°	1,395.16	1,395.16	1,395.16
40.00°	864.98	864.98	864.98
42.50°	383.01	383.01	383.01
45.00°	255.58	255.58	255.58
47.50°	198.82	198.82	198.82
50.00°	159.87	159.87	159.87
52.50°	124.62	124.62	124.62
55.00°	98.40	98.40	98.40
57.50°	74.16	74.16	74.16
60.00°	56.36	56.36	56.36
62.50°	40.03	40.03	40.03
65.00°	29.93	29.93	29.93
67.50°	21.26	21.26	21.26
70.00°	16.54	16.54	16.54
72.50°	12.59	12.59	12.59
75.00°	10.42	10.42	10.42
77.50°	8.70	8.70	8.70
80.00°	7.61	7.61	7.61
82.50°	7.61	7.61	7.61
85.00°	6.67	6.67	6.67
87.50°	6.45	6.45	6.45
90.00°	5.04	5.04	5.04
92.50°	0.00	0.00	0.00
95.00°	0.00	0.00	0.00
97.50°	0.00	0.00	0.00
100.00°	0.00	0.00	0.00
102.50°	0.00	0.00	0.00
105.00°	0.00	0.00	0.00
107.50°	0.00	0.00	0.00
110.00°	0.00	0.00	0.00
112.50°	0.00	0.00	0.00

### Coefficients of Utilization – Zonal Cavity Method

Values are lumens delivered to the workplane.

	<b>pfc</b>	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	0%
	<b>pcc</b>	80%	80%	80%	80%	70%	70%	70%	70%	50%	50%	50%	30%	30%	30%	10%	10%	0%
	<b>pw</b>	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	30%
<b>RCR</b>	<b>0</b>	8,695	8,695	8,695	8,695	8,493	8,493	8,493	8,493	8,115	8,115	8,115	7,769	7,769	7,769	7,452	7,452	7,303
	<b>1</b>	8,323	8,135	7,966	7,814	8,145	7,978	7,827	7,690	7,684	7,564	7,454	7,413	7,319	7,232	7,164	7,092	6,951
	<b>2</b>	7,955	7,628	7,357	7,130	7,797	7,503	7,258	7,050	7,270	7,069	6,896	7,054	6,892	6,749	6,855	6,725	6,609
	<b>3</b>	7,602	7,174	6,842	6,578	7,461	7,074	6,770	6,525	6,886	6,631	6,422	6,712	6,500	6,322	6,551	6,376	6,255
	<b>4</b>	7,267	6,767	6,400	6,120	7,141	6,686	6,346	6,084	6,532	6,242	6,013	6,390	6,143	5,944	6,258	6,049	5,938
	<b>5</b>	6,952	6,400	6,015	5,730	6,839	6,333	5,974	5,705	6,207	5,894	5,655	6,089	5,819	5,606	5,979	5,746	5,558
	<b>6</b>	6,656	6,069	5,675	5,393	6,554	6,013	5,643	5,374	5,908	5,582	5,339	5,810	5,523	5,303	5,717	5,466	5,269
	<b>7</b>	6,378	5,769	5,373	5,096	6,287	5,722	5,348	5,083	5,633	5,300	5,057	5,550	5,253	5,031	5,472	5,207	5,006
	<b>8</b>	6,120	5,495	5,103	4,833	6,037	5,456	5,083	4,823	5,380	5,044	4,804	5,309	5,006	4,784	5,243	4,970	4,766
	<b>9</b>	5,878	5,246	4,859	4,598	5,803	5,212	4,843	4,591	5,148	4,811	4,576	5,087	4,781	4,561	5,029	4,751	4,547
	<b>10</b>	5,653	5,019	4,639	4,386	5,585	4,989	4,626	4,381	4,933	4,600	4,369	4,880	4,574	4,358	4,830	4,550	4,347

### Cone of Light

Mtg Height	Light Level	Beam Diameter
5.5 ft	635.3 fc	2.4 ft
6.5 ft	454.8 fc	2.9 ft
7.5 ft	341.6 fc	3.3 ft
8.0 ft	300.3 fc	3.5 ft
10.0 ft	192.2 fc	4.4 ft
12.0 ft	133.4 fc	5.3 ft
14.0 ft	98.0 fc	6.2 ft
16.0 ft	75.1 fc	7.1 ft
20.0 ft	48.0 fc	8.8 ft
24.0 ft	33.4 fc	10.6 ft
28.0 ft	24.5 fc	12.4 ft

### Average Luminaire Luminance [cd/m²]

	0.00°	45.00°	90.00°
<b>0.00°</b>	1,053,449	1,053,449	1,053,449
<b>45.00°</b>	19,815	19,815	19,815
<b>55.00°</b>	9,405	9,405	9,405
<b>65.00°</b>	3,883	3,883	3,883
<b>75.00°</b>	2,208	2,208	2,208
<b>85.00°</b>	4,197	4,197	4,197

### UGR CIE 190:2010

<b>Ceiling reflectance</b>		<b>0.7</b>	<b>0.7</b>	<b>0.5</b>	<b>0.5</b>	<b>0.3</b>	<b>0.7</b>	<b>0.7</b>	<b>0.5</b>	<b>0.5</b>	<b>0.3</b>
<b>Wall reflectance</b>		<b>0.5</b>	<b>0.3</b>	<b>0.5</b>	<b>0.3</b>	<b>0.3</b>	<b>0.5</b>	<b>0.3</b>	<b>0.5</b>	<b>0.3</b>	<b>0.3</b>
<b>Plane reflectance</b>		<b>0.2</b>	<b>0.2</b>	<b>0.2</b>	<b>0.2</b>	<b>0.2</b>	<b>0.2</b>	<b>0.2</b>	<b>0.2</b>	<b>0.2</b>	<b>0.2</b>
<b>Room dimensions</b>		<b>Viewed crosswise</b>					<b>Viewed endwise</b>				
<b>2H</b>	<b>2H</b>	9.5	10.4	9.8	10.7	11.1	9.5	10.4	9.8	10.7	11.1
	<b>3H</b>	9.7	10.5	10.1	10.9	11.2	9.7	10.5	10.1	10.9	11.2
	<b>4H</b>	9.8	10.5	10.2	10.9	11.3	9.8	10.5	10.2	10.9	11.3
	<b>6H</b>	9.8	10.5	10.2	10.9	11.3	9.8	10.5	10.2	10.9	11.3
	<b>8H</b>	9.9	10.5	10.3	10.9	11.3	9.9	10.5	10.3	10.9	11.3
	<b>12H</b>	10.0	10.6	10.4	11.0	11.4	10.0	10.6	10.4	11.0	11.4
<b>4H</b>	<b>2H</b>	9.4	10.2	9.9	10.6	11.0	9.4	10.2	9.9	10.6	11.0
	<b>3H</b>	9.8	10.4	10.2	10.8	11.2	9.8	10.4	10.2	10.8	11.2
	<b>4H</b>	9.9	10.4	10.3	10.9	11.3	9.9	10.4	10.3	10.9	11.3
	<b>6H</b>	10.0	10.5	10.5	10.9	11.4	10.0	10.5	10.5	10.9	11.4
	<b>8H</b>	10.1	10.6	10.6	11.0	11.5	10.1	10.6	10.6	11.0	11.5
	<b>12H</b>	10.3	10.7	10.8	11.2	11.7	10.3	10.7	10.8	11.2	11.7
<b>8H</b>	<b>4H</b>	9.8	10.3	10.3	10.7	11.2	9.8	10.3	10.3	10.7	11.2
	<b>6H</b>	10.0	10.4	10.6	10.9	11.4	10.0	10.4	10.6	10.9	11.4
	<b>8H</b>	10.3	10.6	10.8	11.1	11.6	10.3	10.6	10.8	11.1	11.6
	<b>12H</b>	10.6	10.9	11.1	11.4	12.0	10.6	10.9	11.1	11.4	12.0
<b>12H</b>	<b>4H</b>	9.8	10.2	10.3	10.6	11.1	9.8	10.2	10.3	10.6	11.1
	<b>6H</b>	10.0	10.4	10.6	10.8	11.4	10.0	10.4	10.6	10.8	11.4
	<b>8H</b>	10.3	10.6	10.9	11.1	11.7	10.3	10.6	10.9	11.1	11.7

Corrected UGR values based on total output lumens

SHR = 1.0