

SPEC21-0102

Project Date	8 / 27 / 2021
Project Type	N/A
Project Quote #	
Project Name	Watertown Atrium
Project Qty.	Multi
Location	Dry / Damp
Source Lumens	Must Be Specified Per Globe (5,500L Max)
Kelvin / CCT	3,000K
Distribution	General
CRI	90 CRI Min.
Voltage	120V / 277V
Dim Protocol	0-10V
Lensing	White Acrylic Globe
Finish	Refer To Drawing Notes
Mount Length	Refer To Drawing Notes
Required Listing	N/A
Other	N/A
Customer Signature	

